## REVIEW FOR APPLICABILITY OF/COMPLIANCE WITH ORDINANCES/POLICIES

## FOR PURPOSES OF CONSIDERATION OF Village Place Apartments Site Plan PDS2015-STP-15-026; LOG NO. PDS2015-ER-15-09-007

June 13, 2018

			– Does the proposed project conform to the dinance findings?
	YES	NO	NOT APPLICABLE/EXEMPT
boundaries of the of any off-site in Permit/Coastal S	Multiple Spemprovements	ecies Conserv s do not cor Ordinance. T	improvements are located outside of the ration Program, the project site and locations ntain habitats subject to the Habitat Loss nerefore, conformance to the Habitat Lossings is not required.
<u>II. MSCP/BMO</u> - I Program and Biol		· •	conform to the Multiple Species Conservation e?
	YES	NO	NOT APPLICABLE/EXEMPT
located outside	of the boun	daries of the	ovements related to the proposed project are Multiple Species Conservation Program. e Species Conservation Program and the ed.
III. GROUNDWA			the project comply with the requirements of nce?
	YES	NO	NOT APPLICABLE/EXEMPT
The project will o	btain its wate	er supply from	the Ramona Municipal Water District which

obtains water from surface reservoirs and/or imported sources. The project will not use

any groundwater for any purpose, including irrigation or domestic supply.

## **IV. RESOURCE PROTECTION ORDINANCE** - Does the project comply with:

The wetland and wetland buffer regulations (Sections 86.604(a) and (b)) of the Resource Protection Ordinance?	YES	NO	NOT APPLICABLE/EXEMPT
The Floodways and Floodplain Fringe section (Sections 86.604(c) and (d)) of the Resource Protection Ordinance?	YES	NO	NOT APPLICABLE/EXEMPT
The Steep Slope section (Section 86.604(e))?	YES	NO	NOT APPLICABLE/EXEMPT
The Sensitive Habitat Lands section (Section 86.604(f)) of the Resource Protection Ordinance?	YES ⊠	NO	NOT APPLICABLE/EXEMPT
The Significant Prehistoric and Historic Sites section (Section 86.604(g)) of the Resource Protection Ordinance?	YES	NO	NOT APPLICABLE/EXEMPT

**Wetland and Wetland Buffers**: The site contains no wetland habitats as defined by the San Diego County Resource Protection Ordinance. The site does not have a substratum of predominately undrained hydric soils, the land does not support, even periodically, hydric plants, nor does the site have a substratum that is non-soil and is saturated with water or covered by water at some time during the growing season of each year. Therefore, it has been found that the proposed project complies with Sections 86.604(a) and (b) of the Resource Protection Ordinance.

**Floodways and Floodplain Fringe:** The project is not located near any floodway or floodplain fringe area as defined in the resource protection ordinance, nor is it near a watercourse plotted on any official County floodway or floodplain map. Therefore, it has been found that the proposed project complies with Sections 86.604(c) and (d) of the Resource Protection Ordinance.

**Steep Slopes:** Slopes with a gradient of 25 percent or greater and 50 feet or higher in vertical height are required to be placed in open space easements by the San Diego County Resource Protection Ordinance (RPO). There are no steep slopes on the property. Therefore, it has been found that the proposed project complies with Sections 86.604(e) of the RPO.

**Sensitive Habitats:** Sensitive habitat lands include unique vegetation communities and/or habitat that is either necessary to support a viable population of sensitive species, is critical to the proper functioning of a balanced natural ecosystem, or which serves as a functioning wildlife corridor. No sensitive habitat lands were identified on the site as determined by a biological technical report prepared by Vincent Scheidt and dated March 2017. Therefore, it has been found that the proposed project complies with Section 86.604(f) of the RPO

**Significant Prehistoric and Historic Sites:** Based on an analysis of records and prior cultural surveys, it has been determined that the property does not contain any archaeological and/or historical resources. Therefore, it has been found that the proposed project complies with the RPO.

<u>V. STORMWATER ORDINANCE (WPO)</u> - Does the project comply with the County of San Diego Watershed Protection, Stormwater Management and Discharge Control Ordinance (WPO)?

YES	NO	NOT APPLICABLE
$\boxtimes$		

The project Storm Water Quality Management Plan dated April 18, 2018 has been reviewed and is found to be complete and in compliance with the WPO.

<u>VI. NOISE ORDINANCE</u> – Does the project comply with the County of San Diego Noise Element of the General Plan and the County of San Diego Noise Ordinance?

YES	NO	NOT APPLICABLE

The project is comprised of 25 units with group useable outdoor areas which includes a picnic area and children's play area. The project is subject to the County Noise Element which limits exterior noise levels for multi-family developments to 65 dBA CNEL. Based on the accepted noise report and in-house noise review, the project has an increased distance from heavily traveled roadways. Noise sensitive private outdoor areas associated with the project would not be exposed to traffic noise exceeding 65 dBA CNEL. Project related traffic contributions to nearby roadways have been assessed. Due to the project's minimal average daily trips, the project would not result in an off-site direct or cumulative noise impact. In addition, an interior noise study would not be required because levels at the project habitable buildings are not anticipated to exceed 60 dBA CNEL.

The project is also subject to the County Noise Ordinance. Permanent noise sources such as HVAC units are subject to the County Noise Ordinance one-hour average sound level limit at the property line, pursuant to Section 36.404. Mechanical equipment has been assessed, and will not exceed the Noise Ordinance sound level limits at the project property line. The proposed architectural features and HVAC orientation will result in further noise reduction.

Temporary grading operations to prepare the site were also assessed. The construction activities will result in an anticipated (worst-case) eight-hour average combined noise level of less than 75 dBA at the property line. Based on spatial separation of the equipment over the site, the noise levels from the grading are anticipated to comply with the County of San Diego's 75 dBA standard at all project property lines. No blasting or rock crushing is anticipated during the grading operations. Therefore, no impulsive noise sources are expected, and the project will comply with Sections 36.409 & 36.410 of the County Noise Ordinance.